

US Department of Veterans Affairs

Program Contracting Activity Central (PCAC) 6150 Oak Tree Blvd, Suite 300 Independence, Ohio 44131

E85 FUELING STATION

VA Medical Center 3600 30th Street Des Moines, Iowa 50310

IDIQ #VA701-12-D-0038

Task Order #VA701-13-J-0154

LIST OF DRAWINGS

COVER SHEET G-001

CU-101 **EXISTING CONDITIONS**

CU-102 SITE PLAN

MS-101 MECHANICAL PLAN, DETAILS, & SCHEDULE

ELECTRICAL SITE PLAN ES-101




E85 FUEL STATION

Checker


3600 30TH STREET DES MOINES, IA 50310





CONSTRUCTION BID DOCUMENTS





ST. PAUL, MN 55101

ЮR	COVER SHEET
	Approved : Project Director
444 CEDAR STREET, SUITE 1900,	

222514 G-001


Management


Office of


Construction

and Facilities

(2)







UNDERGROUND TANK & BALLAST PAD SCHEDULE

(DRY)

LBS

1700

BALLAST DEPTH HOLD DOWN RODS
PAD OF NUMBER DIA

WEIGHT COVER

LBS

BASIS

DESIGN

XERXES

NOTE

ANK SIZE TANK WALL THICKNESS TANK
DIA. LENGTH BUOYANT INNER OUTER WEIGHT

GAUGE GAUGE

--

FORCE

IN LBS

13'-6"

MARK STORED NUMBER FLUID

 $\mathsf{UT} extsf{-}1$

CONST

NOMINAL

TYP. TANK SIZE DIMENSIONS VARY SLIGHTLY DEPENDING ON MANUFACTURER.

PROVIDE UNDERWRITERS APPROVED TANKS FOR USE WITH E85 FUEL.

2 CONTRACTOR TO PROVIDE TANK FULL OF E85 FUEL AT END OF PROJECT.

TANK BOUYANT FORCE CALCULATED FOR CLEAN WATER (62.4 LBS/CU. FT).

HOLD DOWN ROD NUMBER AND SIZE BASED ON A 5:1 SAFETY FACTOR FOR TURNBUCKLES.

1. PROVIDE HOLD DOWN RODS AND STRAPS PER MANUFACTURER RECOMMENDED STANDARDS.

MATERIAL | CAPACITY

FIBERGLASS 2500

1 1/2" E85 FEED LINE-—CONNECT TO ELECTRONIC FILL CONNECTION MONITORING AND SECONDARY CONTROL PANEL CONTAINMENT — GRADE ── RECOVERY BOX— SECONDARY CONTAINMENT₇ CONTAINMENT DETECTOR \FLUID RESERVOIR PREVENTION VALVE+ DROP TUBE FILL ASSEMBLY —LEVEL GAUGE WITH DIFFUSER -TANK PROBE

ELEVATION

6

/─2'-0" MINIMUM DEPTH OF COVER ALONG LENGTH OF TANK _5' x 5' x 8" THICK CONC. PAD W/ NO. 4 RODS AT 9" O.C. EA. WAT MANHOLE: CAST IRON FRAME & COVER ∕-GRADE GRADE EL = VARIES (899 LOWEST) −36" DIA. x 24" LONG REINFORCED CONC. PIPE -BACKFILL TO BE CLEAN SAND PUDDLED IN PLACE /IRON STRAP BUILDING-TURNBUCKLE FOOTING PROVIDE ANCHORING HARDWARE DEADMEN AND DEADMEN SUPPLIED BY TANK MANUFACTURER

AREA OF EXCAVATION. PROTECT EXISTING UTILITIES FROM DAMAGE

WATER MAINS WILL BE NO MORE THAN 3 FEET FROM WEST EDGE OF

THROUGHOUT CONSTRUCTION. IT IS ANTICIPATED THAT EXISTING

NEW TANK. NOTIFY VA IMMEDIATELY IF LOCATION OF UTILITIES

GEOTECHNICAL REPORT. ALL FOUNDATION EXCAVATIONS SHALL BE

GEOTECH SHALL BE EXCAVATED AND REPLACED WITH PROPERLY

ADJACENT TO EXISTING STRUCTURES OR IMPROVEMENTS SO AS NOT TO DAMAGE OR UNDERMINE FOUNDATIONS, WALLS, SLABS, UTILITIES, ETC. SHORE EXISTING STRUCTURES AS REQUIRED FOR INSTALLATION

FOOTING ANY CLOSER TO THE FOOTING THAN A SLOPE OF TWO

HORIZONTAL (MEASURED FROM EDGE OF FOOTING TO NEAREST POINT

(2) REPORT ACCIDENT BY CALLING (SPECIFY LOCAL FIRE NUMBER).

STRICT ACCORDANCE WITH THE SPECIFICATIONS AND THE

INTERFERES WITH TANK INSTALLATION.

IN EXCAVATION) TO ONE VERTICAL.

(1) USE EMERGENCY STOP BUTTON.

REPORT LOCATION.

COMPACTED FILL.


OF THE TANK.

OBSERVED AND APPROVED BY THE GEOTECH.

GASOLINE STORAGE TANK DETAIL SCALE: NTS

CONSTRUCTION BID DOCUMENTS





ELECTRICAL SITE PLAN
SCALE: 1:5

CONSTRUCTION BID DOCUMENTS

Office of


Construction

and Facilities

Management

PROJECT TEAM REVISIONS





444 CEDAR STREET, SUITE 1900, ST. PAUL, MN 55101

Drawing Title ELECTRICAL SITE PLAN	Project Title E85 FUEL STATION			Project Number 222514 Building Number Drawing number
Approved : Project Director	Location			
	Date 08/1/2014	Checked by Checker	Drawn H. Phillips	ES-101

GENERAL NOTES:

TO INSTALLATION.

A. ALL EXTERIOR CONDUIT SHALL BE THREADED RIGID METAL

UNDERGROUND RUNS IN ACCORDANCE WITH NEC 514.8

C. PROVIDE GROUNDING AND BONDING OF ALL CIRCUITS AND CONDUIT RUNS IN ACCORDANCE WITH NEC 514.16

D. PROVIDE EXPLOSION SEAL FOR ALL CONDUITS WITHIN 3 FT

E. CONFIRM LOCATION OF ALL EQUIPMENT WITH OWNER PRIOR

1. PROVIDE CONNECTION TO FUEL DISPENSER. ROUTE (2)#12, (1)#12 GRD CIRCUIT TO NEW 20/1 CIRCUIT BREAKER IN EXISTING PANEL B-9-6. BREAKER TO MATCH EXISTING. CONDUIT SHALL ENTER BUILDING ABOVE GRADE. CIRCUIT

2. PROVIDE POWER CONNECTION FOR TANK MONITORING AND

DISPENSER MONITORING. ROUTE (2)#12, (1)#12 GRD CIRCUIT TO NEW 20/1 CIRCUIT BREAKER IN EXISTING PANEL SERVING AREA. BRÉAKER TO MATCH EXISTING. CIRCUIT SHALL BE

3. PROVIDE EXTERIOR RATED EPO. EPO TO OPEN CONTACTORS

ENGRAVED ON RED BACKGROUND. TEXT SHALL BE ARIAL FONT 1-1/2" IN HEIGHT. CONTRACTOR SHALL SUBMIT

SIGNAGE TEMPLATE FOR APPROVAL PRIOR TO FABRICATION.

5. ROUTE 1" CONDUIT FROM FUEL OIL CONTROL PANEL THROUGH COMMUNICATION-RATED CONTACTOR TO FUEL DISPENSER FOR

4-POLE, CONTACTORS IN AN ENCLOSURE. ENCLOSURE SHALL BE SIZED TO ALLOW FOR A SECOND SET OF

7. ROUTE 1" CONDUIT FROM FUEL OIL CONTROL PANEL THROUGH COMMUNICATION—RATED CONTACTOR TO UNDERGROUND

EMERGENCY FUEL SYSTEM SHUTDOWN. ROUTE CONDUIT BACK

TO NEAREST COMMUNICATIONS CLOSET FOR CONNECTION TO EXISTING TELECOMMUNICATION SYSTEM.

ENCLOSURE. ENCLOSURE SHALL BE SIZED TO ALLOW FOR A SECOND SET OF CONTACTORS TO BE ADDED IN THE FUTURE. POWER WIRING SHALL BE ROUTED THROUGH CONTACTORS

SIGN NOTING "GASOLINE PUMP EMERGENCY SHUT OFF SWITCH". SIGNAGE SHALL CONSIST OF WHITE TEXT

4. PROVIDE TWO 20A, 120V, 3-POLE CONTACTORS IN AN

6. PROVIDE TWO LOW VOLTAGE, COMMUNICATION RATED,

CONTACTORS TO BE ADDED IN THE FUTURE.

STORAGE TANK FOR COMMUNICATION WIRING.

8. FUEL OIL CONTROL PANEL PROVIDED BY MECHANICAL. 9. PROVIDE CONNECTION FOR EMERGENCY PHONE. PHONE SHALL BE USED FOR COMMUNICATION IN EVENT OF

OPENING HOT, NEUTRAL, AND GROUND.

COMMUNICATION WIRING.

FOR POWER AND COMMUNICATION SIMULTANEOUSLY. PROVIDE

B. RIGID NONMETALLIC CONDUIT SHALL BE ALLOWED FOR

OF THE POINT OF EMERGENCE ABOVE GRADE.

SHALL BE ROUTED THROUGH CONTACTOR.

ROUTED THROUGH CONTACTOR.

ALL INTERIOR CONDUIT MAY BE EMT.

CONDUIT OR THREADED STEEL INTERMEDIATE METAL CONDUIT.